

October 2, 2017

Amendment to the July 2016 Sanitary Sewer Standards, Urbana & Champaign Sanitary District and Affiliated Communities Champaign, Urbana, and Savoy

Minimum Constructed Slope and Manhole Pipe Connection Revisions- Effective November 1, 2017

190.00 Minimum Constructed Slope: For terminal sewer runs the last 700-feet shall have a minimum pipe slope of 0.60% slope for an 8-inch diameter line.

Manhole Detail Revision #1: A-LOK gaskets shall also be permitted for pipe inlet and outlet openings in addition to the KOR-N-SEAL gaskets.

Approved and Adopted by:

Urbana & Champaign Sanitary District

By: *Rud Manner*
Executive Director

City of Urbana, Illinois

By: *William A. Gray*
Public Works Director

City of Champaign, Illinois

David Clark
City Engineer

Village of Savoy, Illinois

John A. Kasper
Public Works Director